



NEXTDAY INSPECT
46179 WESTLAKE DR UNIT 200
STERLING, VA 20165

CERTIFICATE OF BULK ASBESTOS ANALYSIS

Prepared for:	CLIENT NAME
Phone Number:	(703) 000-0000
Email Address:	alkurd@nvre.net;info@nextdayinspect.com
Project Name:	SFD Asbestos Testing
Test Location:	10000 SAMPLE DR SAMPLE, MD 100000
Chain of Custody	1000000
#: Date Sampled:	November 8, 2020
Date Reported:	November 16, 2020

Azmi Alkurd
Asbestos Analyst

For more information please contact NextDay Inspect at (703) 450-6398 or email info@nextdayinspect.com



SFD

10000 SAMPLE DR
Sample, MD 10000

November 8, 2020

Client ID	PRO-LAB ID	LOCATION	Asbestos Mineral Percentage							COMMENTS
			CH	AM	CR	AN	TR	AC	ND	
	111620-1052	WHITE BASEMENT CEILING	0	0	0	0	0	0	ND	5% Mineral Wool 55% Cellulose 30% Perlite 10% Binders
	111620-1053	GRAY SIDING-NEW ADDITION	25	0	0	0	0	0		75% Binders
	111620-1054	GRAY SIDING-ORIGINAL STRUCTURE	25	0	0	0	0	0		75% Binders

CH=Chrysotile AM=Amosite
 CR=Crocidolite AN=Anthophyllite
 TR=Tremolite AC=Actinolite
 ND=None detected